



# TEST REPORT

우 31035 충남 천안시 서북구 직산읍 직산로 136 충남테크노파크  
종합지원센터 1202호

TEL (041)589-0010

FAX (041)589-0012

성적서번호 : TAN-003963

접 수 일 자 : 2016년 06월 28일

대 표 자 : 이석우

시험완료일자 : 2016년 07월 06일

업 체 명 : 한국하니소(주)

주 소 : 충청남도 당진시 송악읍 부곡공단1길 70

시 료 명 : ISOVER WEATHERPROOF 48K(이소바 웨더프루프 48K)

## 시험결과

시험항목	단위	시료구분	결과치	시험방법
단기흡수율	kg/m <sup>2</sup>	-	0.24	ISO 29767 : 2008

\* 용 도 : 품질관리용

- 비 고 : 1. 이 성적서는 의뢰자가 제시한 시료 및 시료명으로 시험한 결과로써 전체 제품에 대한 품질을 보증하지 않으며, 성적서의 진위확인은 홈페이지(www.ktr.or.kr) 또는 QR code로 확인 가능합니다.  
2. 이 성적서는 홍보, 선전, 광고 및 소송용 등으로 사용될 수 없으며, 용도 이외의 사용을 금합니다.  
3. 이 성적서는 원본(등본 포함)만 유효하며, 사본 및 전자 인쇄본/파일본은 결과치 참고용입니다.

*Park Joo-ick*

작성자 : 박주익  
E-mail: jooick@ktr.or.kr

*You Seok*

기술책임자 : 유석  
Tel : 1577-0091(ARS ①-④)

2016년 07월 06일

**KTR**

한국화학융합시험연구원장



위변조 확인용 QR code

Page : 1 of 1

전자문서본은 시험결과에 대한 참고용입니다.

전자문서본(Electronic Copy)



# TEST REPORT

136, Jiksan-ro, Jiksan-eup, Seobuk-gu, Cheonan-si, Chungcheongnam-do,  
31035 Rep. of KOREA

TEL 82-41-589-0010 FAX 82-41-589-0012

Report No : TAN-003963

Receipt Date : 2016.06.28.

Representative : Lee Seoku

Test Completion Date : 2016.07.06.

Company name: Hankuk Haniso Co.,Ltd.

Address : 70, Bugokgongdan 1-gil, , Dangjin-si, Chungcheongnam-do, Rep. of KOREA

Sample name : ISOVER WEATHERPROOF 48K

## Test Results

TEST ITEM	UNIT	SAMPLE	RESULT	TEST METHOD
short-term water absorption	kg/m <sup>2</sup>	-	0.24	ISO 29767 : 2008

- Usage of Report: QUALITY CONTROL

- NOTE :
1. The test results of this test report are only limited in to the samples and sample names provided by the client and do not guarantee the quality of all products of the client. You can check website (www.ktr.or.kr) or QR code to verify the authenticity of the certificate.
  2. This test report shall be used only within the purpose of its defined usage and shall not be used for public relation, advertisement and lawsuit.
  3. This test report is only valid when printed on KTR original report paper with hologram and when re-issued by KTR. The copy and the electronic file of the test report are only for reference.

*Park Joo-ick*

Tested by Park Joo-ick  
E-mail: jooick@ktr.or.kr

*You Seok*

Technical Manager: You Seok  
Tel: 1577-0091(ARS ①-④)

2016.07.06.

**Korea Testing & Research Institute**

President



QR Code for forgery

Page: 1 of 1

Electronic copy is for your reference only.

전자문서본(Electronic Copy)